## **DATASHEET - BZME1-A16**



Circuit-breaker, 1p, 16A

Part no. BZME1-A16
Catalog No. 109707
Alternate Catalog BZME1-A16



Similar to illustration

## Design verification as per IEC/EN 61439

Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	16
Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	3.4
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
$10.2.3.3\ Verification\ of\ resistance\ of\ insulating\ materials\ to\ abnormal\ heat\ and\ fire\ due\ to\ internal\ electric\ effects$			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must b observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## **Technical data ETIM 7.0**

 $Low-voltage\ industrial\ components\ (EG000017)\ /\ Power\ circuit-breaker\ for\ trafo/generator/installation\ protection\ (EC000228)$ 

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

Rated voltage  Rated short-circuit breaking capacity Icu at 400 V, 50 Hz  Rated short-circuit break	protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])		
Rated short-circuit breaking capacity Icu at 400 V, 50 Hz  kA  18  Overload release current setting  A  0 - 0  Adjustment range short-term delayed short-circuit release  A  0 - 0  Adjustment range undelayed short-circuit release  A  256 - 384  Integrated earth fault protection  Type of electrical connection of main circuit  Screw connection	Rated permanent current lu	Α	16
Overload release current setting  A 0 - 0  Adjustment range short-term delayed short-circuit release  A 0 - 0  Adjustment range undelayed short-circuit release  A 256 - 384  Integrated earth fault protection  Type of electrical connection of main circuit  Screw connection	Rated voltage	V	415 - 415
Adjustment range short-term delayed short-circuit release  Adjustment range undelayed short-circuit release  A 0 - 0  Adjustment range undelayed short-circuit release  A 256 - 384  Integrated earth fault protection  Type of electrical connection of main circuit  Screw connection	Rated short-circuit breaking capacity Icu at 400 V, 50 Hz	kA	18
Adjustment range undelayed short-circuit release  A 256 - 384  Integrated earth fault protection  No  Type of electrical connection of main circuit  Screw connection	Overload release current setting	Α	0 - 0
Integrated earth fault protection  No  Type of electrical connection of main circuit  Screw connection	Adjustment range short-term delayed short-circuit release	Α	0 - 0
Type of electrical connection of main circuit  Screw connection	Adjustment range undelayed short-circuit release	Α	256 - 384
	Integrated earth fault protection		No
Device construction Built-in device fixed built-in technique	Type of electrical connection of main circuit		Screw connection
	Device construction		Built-in device fixed built-in technique

Suitable for DIN rail (top hat rail) mounting	No
DIN rail (top hat rail) mounting optional	Yes
Number of auxiliary contacts as normally closed contact	0
Number of auxiliary contacts as normally open contact	0
Number of auxiliary contacts as change-over contact	0
With switched-off indicator	No
With under voltage release	No
Number of poles	3
Position of connection for main current circuit	Front side
Type of control element	Rocker lever
Complete device with protection unit	Yes
Motor drive integrated	No
Motor drive optional	No
Degree of protection (IP)	IP20