DATASHEET - BZMD1-A32-BT



Circuit-breaker, 1p, 32A, box terminal

Part no. BZMD1-A32-BT Catalog No. 109742 Alternate Catalog BZMD1-A32-BT No.



Similar to illustration

Design verification as per IEC/EN 61439

| Rated operational current for specified heat dissipation | In | Α | 32 |
|---|------------------|---|--|
| Equipment heat dissipation, current-dependent | P _{vid} | W | 7.7 |
| C/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$ | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction |

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

| Rated permanent current lu A 32 Rated voltage V 415 - 415 Rated short-circuit breaking capacity lcu at 400 V, 50 Hz kA 15 | |
|---|--|
| | |
| Rated short-circuit breaking capacity Icu at 400 V, 50 Hz kA 15 | |
| | |
| Overload release current setting A 0 - 0 | |
| Adjustment range short-term delayed short-circuit release A 0 - 0 | |
| Adjustment range undelayed short-circuit release A 320 - 480 | |
| Integrated earth fault protection No | |
| Type of electrical connection of main circuit Frame clamp | |
| Device construction Built-in device fixed built-in technique | |
| Suitable for DIN rail (top hat rail) mounting No | |

| Yes |
|--------------|
| 0 |
| 0 |
| 0 |
| No |
| No |
| 3 |
| Front side |
| Rocker lever |
| Yes |
| No |
| No |
| IP20 |
| |