DATASHEET - BZMD1-A100-BT



Circuit-breaker, 1p, 100A, box terminal

Part no. BZMD1-A100-BT Catalog No. 109757 Alternate Catalog BZMD1-A100-BT No.



Similar to illustration

Design verification as per IEC/EN 61439

| Design verincation as per 126/214 01433 | | | |
|--|------------------|---|--|
| Technical data for design verification | | | |
| Rated operational current for specified heat dissipation | In | Α | 100 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 31.1 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must lobserved. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

| protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013]) | | |
|---|----|--|
| Rated permanent current lu | А | 100 |
| Rated voltage | V | 415 - 415 |
| Rated short-circuit breaking capacity Icu at 400 V, 50 Hz | kA | 15 |
| Overload release current setting | А | 0 - 0 |
| Adjustment range short-term delayed short-circuit release | А | 0 - 0 |
| Adjustment range undelayed short-circuit release | А | 800 - 1200 |
| Integrated earth fault protection | | No |
| Type of electrical connection of main circuit | | Frame clamp |
| Device construction | | Built-in device fixed built-in technique |
| Suitable for DIN rail (top hat rail) mounting | | No |

| Number of auxiliary contacts as normally closed contact Number of auxiliary contacts as normally open contact Number of auxiliary contacts as change-over contact No Nith switched-off indicator No No Number of poles Position of connection for main current circuit Type of control element Complete device with protection unit O O O O O O O O O O O O O | | |
|--|---|--------------|
| Number of auxiliary contacts as normally open contact Number of auxiliary contacts as change-over contact No With switched-off indicator No With under voltage release No No Number of poles Position of connection for main current circuit Type of control element Complete device with protection unit O O O O O O O O O O O O O | DIN rail (top hat rail) mounting optional | Yes |
| Number of auxiliary contacts as change-over contact No With switched-off indicator No With under voltage release No Number of poles Sosition of connection for main current circuit Front side Type of control element Complete device with protection unit O No No Rocker lever Yes | Number of auxiliary contacts as normally closed contact | 0 |
| With switched-off indicator With switched-off indicator With under voltage release No Number of poles Sosition of connection for main current circuit Type of control element Complete device with protection unit No Rocker lever Yes | Number of auxiliary contacts as normally open contact | 0 |
| Nith under voltage release No Number of poles 2 osition of connection for main current circuit Front side Rocker lever Complete device with protection unit No Yes | Number of auxiliary contacts as change-over contact | 0 |
| Number of poles 2 Sosition of connection for main current circuit 3 Front side Front side Rocker lever Complete device with protection unit Yes | With switched-off indicator | No |
| Position of connection for main current circuit Front side Rocker lever Complete device with protection unit Yes | With under voltage release | No |
| Type of control element Complete device with protection unit Rocker lever Yes | Number of poles | 3 |
| Complete device with protection unit Yes | Position of connection for main current circuit | Front side |
| | Type of control element | Rocker lever |
| Material deliver interested | Complete device with protection unit | Yes |
| violor unive integrated NO | Motor drive integrated | No |
| Motor drive optional No | Motor drive optional | No |
| Degree of protection (IP) | Degree of protection (IP) | IP20 |