DATASHEET - PFR-5-110AC

Earth-leakage circuit-breaker 0, 03-5 A, 110AC



Part no. Catalog No.

PFR-5-110AC 116963



Similar to illustration

Delivery program

Rated fault currents	I _{Δn}	А	0.03, 0.1, 0.3, 0.5, 1, 3, 5
Description			Adjustable fault current and delay time Fault current early warning by flashing, red LED Pulse-current sensitive Integrated auxiliary contact (1 C/O) Ring-type transformer must also be ordered not UL/CSA approved
Rated control voltage	Us	V	110 V AC 50/60Hz
Notes			
Adjustable fault current: 0.03, 0.1, 0.3, 0.5, 1, 3, 5 A			

Adjustable delay time: 0.02, 0.1, 0.3, 0.5, 1, 3, 5 A

Technical data

Electrical					
Standards			IEC/EN 60947-2, IEC 755, IEC 1008, IEC 1009		
Sensitivity			Pulse current sensitive, type A		
Rated control voltage	Us	V AC	110 ±20% (50/60 Hz)		
Motor rating	Pe	W	3		
Rated fault currents	I _{Δn}	А	0.03, 0.1, 0.3, 0.5, 1, 3, 5		
Delay time	t _v	s	0.02, 0.1, 0.3, 0.5, 1, 3, 5		
Relay contacts			1 integrated changeover contact		
Rated voltage of the relay contact		V AC/DC	250/100		
Rated current of the relay contact		А	6		
Mechanical					
Standard front dimension		mm	45		
Enclosure height		mm	85		
Device width		mm	45		
Mounting			Snap fixing, top-hat rail DIN 46277, IEC/EN 60715		
Terminals top and bottom			Box terminals		
Terminal protection			Finger/back-of-hand proof to BGV A2, VDE 106 part 100		
Terminal capacities		mm ²	2 x 0.75 - 2.5 solid, 2 x 0.75 - 1.5 flexible/with ferrules		
Sealability			Setting buttons		
Ambient temperature					
Operation		°C	-10 - +50		

Design verification as per IEC/EN 61439

•			
Technical data for design verification			
Operating ambient temperature min.	٩(С	-10
Operating ambient temperature max.	٩(С	50
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.


10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Residual current release for power circuit breaker (EC001021)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Fault current switch for circuit breakers (ecl@ss10.0.1-27-37-04-11 [AKF009013]) ٧ 88 - 132 Rated control supply voltage Us at AC 50HZ Rated control supply voltage Us at AC 60HZ ٧ 88 - 132 Rated control supply voltage Us at DC ٧ 0 - 0 Rated fault current А 0.03 - 5 5000 Max. power on-delay time ms Yes Delay adjustable ٧ 132 Max. rated operation voltage Ue





Additional product information (links)

IL01219036Z (AWA1230-2214) Residual-current relay: converter for earth-leakage circuit-breaker

IL01219036Z (AWA1230-2214) Residual-current https://es-assets.eaton.com/DOCUMENTATION/AWA_INSTRUCTIONS/IL01219036Z2011_01.pdf relay: converter for earth-leakage circuit-breaker