## DATASHEET - NZMS3-VE630-SVE



Circuit-breaker, 3 p, 630A, plug-in module

NZMS3-VE630-SVE 168527 g NZMS3-VE630-SVE



Alternate Catalog No. EL-Nummer (Norway)

Catalog No.

Part no.

0004357602

## Design verification as per IEC/EN 61439

| Technical data for design verification   |                  |   |  |
|--|------------------|---|--|
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub> | W | 119.07   |
| IEC/EN 61439 design verification   |                  |   |  |
| 10.2 Strength of materials and parts   |                  |   |  |
| 10.2.2 Corrosion resistance  |                  |   | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |                  |   | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                  |   | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                  |   | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                  |   | Meets the product standard's requirements.   |
| 10.2.5 Lifting   |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact   |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions  |                  |   | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances   |                  |   | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components   |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections  |                  |   | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |                  |   | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |                  |   |  |
| 10.9.2 Power-frequency electric strength   |                  |   | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   |                  |   | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   |                  |   | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   |                  |   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating   |                  |   | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility  |                  |   | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function  |                  |   | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

## **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

| А  | 630                               |
|----|-----------------------------------|
| V  | 690 - 690                         |
| kA | 65                                |
| А  | 315 - 630                         |
| А  | 630 - 6300                        |
| А  | 1260 - 7560                       |
|    | No                                |
|    | Screw connection                  |
|    | Built-in device plug-in technique |
|    | No                                |
|    | V<br>KA<br>A<br>A                 |

| DIN rail (top hat rail) mounting optional               | No           |
|---|--------------|
| Number of auxiliary contacts as normally closed contact | 0            |
| Number of auxiliary contacts as normally open contact   | 0            |
| Number of auxiliary contacts as change-over contact     | 0            |
| With switched-off indicator                             | No           |
| With under voltage release                              | No           |
| Number of poles   | 3            |
| Position of connection for main current circuit         | Back side    |
| Type of control element                                 | Rocker lever |
| Complete device with protection unit                    | Yes          |
| Motor drive integrated                                  | No           |
| Motor drive optional                                    | Yes          |
| Degree of protection (IP)                               | IP20         |