DATASHEET - NZMS3-4-VE400-SVE



Circuit-breaker, 4 p, 400A, plug-in module

NZMS3-4-VE400-SVE 168536 **Alternate Catalog** NZMS3-4-VE400-SVE



EL-Nummer 0004357606

Design verification as per IEC/EN 61439

Part no.

No.

Catalog No.

(Norway)

Technical data for design verification			
Equipment heat dissipation, current-dependent	P _{vid}	W	72
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

Rated permanent current lu A 400 Rated voltage V 690 - 690 Rated short-circuit breaking capacity lcu at 400 V, 50 Hz KA 65 Overload release current setting A 400 - 400 Adjustment range short-term delayed short-circuit release A 60 - 400 Adjustment range undelayed short-circuit release A 800 - 4400 Integrated earth fault protection No Screw connection	
Rated short-circuit breaking capacity lcu at 400 V, 50 Hz KA 65 Overload release current setting A 200 - 400 Adjustment range short-term delayed short-circuit release A 400 - 4000 Adjustment range undelayed short-circuit release A 800 - 4400 Integrated earth fault protection Integrated earth fault protection No	
Overload release current setting A 200 - 400 Adjustment range short-term delayed short-circuit release A 400 - 4000 Adjustment range undelayed short-circuit release A 800 - 4000 Integrated earth fault protection No No	
Adjustment range short-term delayed short-circuit release A 400 - 4000 Adjustment range undelayed short-circuit release A 800 - 4400 Integrated earth fault protection Integrated earth fault protection No	
Adjustment range undelayed short-circuit release A 800 - 4400 Integrated earth fault protection No	
Integrated earth fault protection No	
Type of electrical connection of main circuit Screw connection	
Device construction Built-in device plug-in technique	
Suitable for DIN rail (top hat rail) mounting No	
DIN rail (top hat rail) mounting optional No	

Motor drive integrated Motor drive optional	No Yes
Complete device with protection unit	Yes
Type of control element	Rocker lever
Position of connection for main current circuit	Back side
Number of poles	4
With under voltage release	No
With switched-off indicator	No
Number of auxiliary contacts as change-over contact	0
Number of auxiliary contacts as normally open contact	0
Number of auxiliary contacts as normally closed contact	0