DATASHEET - NZMH3-4-A500-SVE



Circuit-breaker, 4p, 500A, withdrawable unit

NZMH3-4-A500-SVE Part no. Catalog No. 168893

Alternate Catalog NZMH3-4-A500-SVE

EL-Nummer (Norway)

0004357616





| Delivery program | | | |
|---|----------------------|----|-----------------------------|
| Protective function | | | System and cable protection |
| Standard/Approval | | | IEC |
| Switching capacity | | | |
| 400/415 V 50 Hz | I _{cu} | kA | 150 |
| Rated current = rated uninterrupted current | | | |
| Rated current = rated uninterrupted current | $I_n = I_u$ | Α | 500 |
| Neutral conductor | % of phase conductor | % | 100 |
| Setting range | | | |
| Overload trip | | | |
| 中 | l _r | Α | 400 - 500 |
| Main pole | I _r | Α | 400 - 500 |
| Short-circuit releases | | | |
| Non-delayed | $I_i = I_n x \dots$ | | 6 - 10 |

Technical data

General

| Ambient temperature | | | |
|---|-----------------|----|-------------|
| Ambient temperature, storage | | °C | - 40 - + 70 |
| Operation | | °C | -25 - +70 |
| Circuit-breakers | | | |
| Rated current = rated uninterrupted current | $I_n = I_u$ | Α | 500 |
| Switching capacity | | | |
| Rated short-circuit breaking capacity I _{cn} | I _{cn} | | |
| Icu to IEC/EN 60947 test cycle 0-t-C0 | lcu | kA | |
| 400/415 V 50/60 Hz | I _{cu} | kA | 150 |
| Ics to IEC/EN 60947 test cycle 0-t-C0-t-C0 | lcs | kA | |
| 500 V DC | I _{cs} | kA | 70 |
| 750 V DC | I _{cs} | kA | 70 |
| | | | |

Design verification as per IEC/EN 61439

| 2001gii 1011110411011 40 poi 120, 211 01 100 | | | |
|--|------------------|----|-------|
| Technical data for design verification | | | |
| Rated operational current for specified heat dissipation | In | Α | 500 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 130.5 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 70 |

| 10.2 Strength of materials and parts | |
|--|--|
| 10.2.2 Corrosion resistance | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | Meets the product standard's requirements. |
| 10.2.5 Lifting | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9 Insulation properties | |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (eci@ss10.0.1-27-37-04-09 [AJZ716013])

| protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013]) | | |
|---|----|-----------------------------------|
| Rated permanent current lu | Α | 500 |
| Rated voltage | V | 690 - 690 |
| Rated short-circuit breaking capacity Icu at 400 V, 50 Hz | kA | 150 |
| Overload release current setting | Α | 400 - 500 |
| Adjustment range short-term delayed short-circuit release | Α | 0 - 0 |
| Adjustment range undelayed short-circuit release | А | 6 - 10 |
| Integrated earth fault protection | | No |
| Type of electrical connection of main circuit | | Screw connection |
| Device construction | | Built-in device plug-in technique |
| Suitable for DIN rail (top hat rail) mounting | | No |
| DIN rail (top hat rail) mounting optional | | No |
| Number of auxiliary contacts as normally closed contact | | 0 |
| Number of auxiliary contacts as normally open contact | | 0 |
| Number of auxiliary contacts as change-over contact | | 0 |
| With switched-off indicator | | No |
| With under voltage release | | No |
| Number of poles | | 4 |
| Position of connection for main current circuit | | Front side |
| Type of control element | | Rocker lever |
| Complete device with protection unit | | Yes |
| Motor drive integrated | | No |
| Motor drive optional | | Yes |
| Degree of protection (IP) | | IP20 |

Additional product information (links)

additional technical information for NZM power switch

 $https://es-assets.eaton.com/DOCUMENTATION/PDF/nzm_technic_de_en.pdf$