DATASHEET - NZMH3-S400-SVE

Part no. Catalog No.

No.

Circuit-breaker, 3p, 400A, withdrawable unit

Alternate Catalog NZMH3-S400-SVE

168918

NZMH3-S400-SVE



Similar to illustration

Delivery program

| Description | | | Motor protection in conjunction with overload relay With short-circuit release Without overload release Ir IEC/EN 60947-4-1, IEC/EN 60947-2 The circuit-breaker fulfills all requirements for AC-3 switching category. |
|--|-----------------------------------|----|--|
| Rated current = rated uninterrupted current | $I_n = I_u$ | А | 400 |
| Switching capacity | | | |
| 400/415 V 50 Hz | I _{cu} | kA | 150 |
| Setting range | | | |
| Short-circuit releases | | | |
| Non-delayed | I _i = I _n x | | 7 - 12.5 |
| Motor rating AC-3 at 400 V 50/60 Hz | | | |
| 380 V 400 V | Р | kW | 200 |
| Rated operational current AC-3 at 400 V 50/60 Hz | | | |
| 400 V | le | А | 349 |
| Technical data General | | | |

Design verification as per IEC/EN 61439


| Technical data for design verification | | | |
|--|------------------|----|-------|
| Rated operational current for specified heat dissipation | In | А | 400 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 72.48 |
| Operating ambient temperature min. | | °C | -25 |



| Operating ambient temperature max. | °C | 70 |
|--|----|--|
| EC/EN 61439 design verification | | |
| 10.2 Strength of materials and parts | | |
| 10.2.2 Corrosion resistance | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | |
| 10.9.2 Power-frequency electric strength | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | Is the panel builder's responsibility. The specifications for the switchgear must l observed. |
| 10.12 Electromagnetic compatibility | | Is the panel builder's responsibility. The specifications for the switchgear must l observed. |
| 10.13 Mechanical function | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

| IECNNICAI data ETIM 7.0 | | | | | |
|---|----|-----------------------------------|--|--|--|
| Low-voltage industrial components (EG000017) / Motor protection circuit-breaker (EC000074) | | | | | |
| Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Motor protection circuit-breaker (ecl@ss10.0.1-27-37-04-01 [AGZ529016]) | | | | | |
| Overload release current setting | А | 0 - 0 | | | |
| Adjustment range undelayed short-circuit release | А | 7 - 12.5 | | | |
| With thermal protection | | No | | | |
| Phase failure sensitive | | No | | | |
| Switch off technique | | Magnetic | | | |
| Rated operating voltage | V | 690 - 690 | | | |
| Rated permanent current lu | А | 400 | | | |
| Rated operation power at AC-3, 230 V | kW | V 132 | | | |
| Rated operation power at AC-3, 400 V | kW | V 200 | | | |
| Type of electrical connection of main circuit | | Other | | | |
| Type of control element | | Rocker lever | | | |
| Device construction | | Built-in device plug-in technique | | | |
| With integrated auxiliary switch | | No | | | |
| With integrated under voltage release | | No | | | |
| Number of poles | | 3 | | | |
| Rated short-circuit breaking capacity Icu at 400 V, AC | kA | 150 | | | |
| Degree of protection (IP) | | IP20 | | | |
| Height | mm | m 215.2 | | | |
| Width | mm | m 140 | | | |
| Depth | mm | m 335 | | | |



Additional product information (links)

additional technical information for NZM power switch

https://es-assets.eaton.com/DOCUMENTATION/PDF/nzm_technic_de_en.pdf