DATASHEET - IZMX16H3-V06F-1



Circuit-breaker, 3 pole, 630A, 66 kA, Selective operation, IEC, Fixed

IZMX16H3-V06F-1 183336

4398010



EL-Nummer (Norway)

Part no. Catalog No.

Delivery program

Product range			Air circuit-breakers/switch-disconnectors
Product range			Open circuit-breakers
Current Range			Up to 4000 A
Protective function			Selective operation
Installation type			Fixed
			Main terminals must be separately ordered.
Construction size			IZMX16
Release system			Electronic release
Standard/Approval			IEC
Number of poles			3 pole
Degree of Protection			IP31 with door seals, IP55 with protective cover
			suitable for zone selectivity optionally fittable by user with comprehensive accessories
Rated current = rated uninterrupted current	$I_n = I_u$	А	630
up to 440 V 50/60 Hz	l _{cu}	kA	66
up to 440 V 50/60 Hz	I _{cs}	kA	50
Overload release, min.	I _r	А	252
Overload release, max.	l _r	А	630
Non-delayed	l _i = l _n x		2 - 15, OFF
Delayed	$I_{sd} = I_r \times \dots$		1,5 - 10

Technical data

General			
Standards			IEC/EN 60947
Ambient temperature			
Storage	8	°C	-20 - +70
Ambient temperature		°C	-20 - +70
Mounting position			30° 30°
			30° 30°
Utilization category			В
Degree of Protection			IP31 with door seals, IP55 with protective cover
Direction of incoming supply			as required
Main conducting paths			
Rated current = rated uninterrupted current	$\mathbf{I}_n = \mathbf{I}_u$	А	630

any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross-sectional area. Temperature rise tests in the specific switchgear can provide	Rated uninterrupted current at 50 °C	l _u	А	630
Name of a start o	Rated uninterrupted current at 60 °C		A	630
NameNa				
Reserve shorts up toUpVACReserve shorts up toUpVACUse inf sectoring segments up toUpVACVACVACRest shorts or entowing toVACVACVACSwitching segments vacVACVACVACny the VADDDPVACVACVACny the VADDDPVACVACVACny the VADDDPVACVACVACny the VADDDPVACVACVACny the VADDDPVACVACVACny the VADDDPVACVACVACny the VADDDPVACVACVACSeed observicitated connet WADDDPVACVACVACSeed Observicitated VADDDPVACVACVACSeed Observicitated VADDDP				
Up on (1) if electrical power retworks up to 100UVRefOur consignation (1) (1) (1) (1) (1) (1) (1) (1) (1) (1)				
Oversite states without origination under states and a paper is a state state and a paper is a state				
Redensional squaresUVNNOSwitch up can be up to the set of the		U	V	
Note the set of				111/3
Rind orbain making capablyLag	-	Ui	V	1000
pic 44 9 5050 kckmkmkmkmup to 49 9 5050 kckm <td></td> <td></td> <td></td> <td></td>				
number of the stand current SUB114Number of the stand current SUB114Number of the stand current SUB114It = 1It = ItIt = ItStand after-forcial branking capacity Inc.It = ItIt = ItIt = 16 (KM SP) contrains streamers Inc. It = CONTRACTIt = ItIt = ItIt = 16 (KM SP) contrains streamers Inc. It = CONTRACTIt = ItIt = ItIt = 16 (KM SP) contrains streamers Inc. It = CONTRACTIt = ItIt = ItIt = 16 (KM SP) contrains streamers Inc. It = CONTRACTIt = ItIt = ItIt = 16 (KM SP) contrains streamers Inc. It = CONTRACTIt = ItIt = ItIt = 16 (KM SP) contrains streamers Inc. It = CONTRACTIt = ItIt = ItIt = 16 (KM SP) contrains streamers Inc. It = CONTRACTIt = ItIt = ItIt = 16 (KM SP) contrains streamers Inc. It = CONTRACTIt = ItIt = ItIt = 16 (KM SP) contrains streamers Inc. It = CONTRACTIt = ItIt = ItIt = 16 (KM SP) contrains streamers Inc. It = CONTRACTIt = ItIt = ItIt = 16 (KM SP) contrains streamers Inc. It = CONTRACTIt = ItIt = ItIt = 16 (KM SP) contrains Inc. It = ItIt = ItItItIt = 16 (KM SP) contrains Inc. ItIt = ItItItItIt = 16 (KM SP) contrains Inc. ItItItItItIt = 16 (KM SP) contrains		I _{cm}		
Net of short-sine will shard current \$380 h/L Kay Kay <td>up to 440 V 50/60 Hz</td> <td>I_{cm}</td> <td>kA</td> <td>145</td>	up to 440 V 50/60 Hz	I _{cm}	kA	145
i = 1 s Ive Name Construction of the section of the sectin of the section of the section of the section of the sect	up to 690 V 50/60 Hz	I _{cm}	kA	88
And due: And base And base And base And base Introduction of sequences by sequences by up to 440 V5000 hr. Key	Rated short-time withstand current 50/60 Hz			
IECER 80947 operating sequence 1 ₁₀ 0+60 In In </td <td>t = 1 s</td> <td>I_{cw}</td> <td>kA</td> <td>42</td>	t = 1 s	I _{cw}	kA	42
up to 240 Y 5060 Hz km km Km Km Km up to 440 Y 5060 Hz km Km Km Km Km up to 580 Y 5060 Hz km Km Km Km Km Up to 540 Y 5060 Hz km Km <t< td=""><td>Rated short-circuit breaking capacity I_{cn}</td><td>I_{cn}</td><td></td><td></td></t<>	Rated short-circuit breaking capacity I _{cn}	I _{cn}		
up to 440 V SNR0 Hz Hz Ka 6 up to 880 V SNR0 Hz Fa Ka 6 up to 880 V SNR0 Hz Fa Ka 6 up to 200 V SNR0 Hz Fa Ka 6 up to 200 V SNR0 Hz Fa Ka 6 up to 800 V SNR0 Hz Fa Ka 6 up to 800 V SNR0 Hz Fa Ka 6 Operating times Fa Ka 6 Obtsing delay via signar release Fa So 6 Total opening delay via signar release Fa So 6 Total opening delay via signar release Fa So 6 Total opening delay via signar release Fa So 6 Total opening delay via signar release Fa So 6 Utespan, mechanical Soveching Fa 6 6 Utespan, mechanical Soveching So 6 6 6 Utespan, electrical Soveching So 6 6 6 6	IEC/EN 60947 operating sequence I _{cu} O-t-CO			
up to 440 V SNR0 Hz Hz Ka 6 up to 880 V SNR0 Hz Fa Ka 6 up to 880 V SNR0 Hz Fa Ka 6 up to 200 V SNR0 Hz Fa Ka 6 up to 200 V SNR0 Hz Fa Ka 6 up to 800 V SNR0 Hz Fa Ka 6 up to 800 V SNR0 Hz Fa Ka 6 Operating times Fa Ka 6 Obtsing delay via signar release Fa So 6 Total opening delay via signar release Fa So 6 Total opening delay via signar release Fa So 6 Total opening delay via signar release Fa So 6 Total opening delay via signar release Fa So 6 Utespan, mechanical Soveching Fa 6 6 Utespan, mechanical Soveching So 6 6 6 Utespan, electrical Soveching So 6 6 6 6	up to 240 V 50/60 Hz	I _{cu}	kA	85
up to 800 V SNO Brit/ up km km </td <td></td> <td></td> <td></td> <td></td>				
IEDECEN 06947 operating sequence Is_0-0-00-00 Image: I				
up to 240 Y 5000 Hz Ls KA 50 up to 560 Y 5000 Hz Ls KA 50 Operating times Ls KA 50 Closing daily via sping release ms 30 30 Total opening delay via shurt release ms 30 30 Total opening delay via undervoltage release ms 30 30 Total opening delay via undervoltage release ms 30 30 Total opening delay via undervoltage release ms 30 30 Total opening delay via undervoltage release ms 30 30 Itespan, mechanical Store time ms 30 Itespan, mechanical vist maintenance Store time Total opening delay via undervoltage release ms 30 Itespan, mechanical vist maintenance Store time Store time 300 300 Itespan, mechanical vist maintenance Store time Store time 300 300 Itespan, mechanical vist maintenance Store time Store time 300 300 300 300		'cu	ка	+2
up to 440 Y 5080 Hz Hz Ka A 5 up to 560 Y 5080 Hz Ls KA 42 2 Operating times				
uo to 890 V 5000 Hz ks Ka 42 Operating times	up to 240 V 50/60 Hz	I _{cs}	kA	50
Operating times Image: Construct of the set of t	up to 440 V 50/60 Hz	I _{cs}	kA	50
Closing delay via spring release a 30 Total opening delay via sund release a 30 Total opening delay via undervoltage release a 30 Total opening delay via undervoltage release a 30 Total opening delay via undervoltage release a 30 Ufespan Total opening delay on non-delayed short-circuit release (up to complete arc quenching) ms 30 Lifespan, mechanical Switching cycles (OW OFF) a 2500 Lifespan, mechanical with maintenance Switching cycles (OW OFF) a 25000 Lifespan, electrical with maintenance Switching cycles (OW OFF) a a Maximum operating frequency Operationsh OFF) a a Maximum operating frequency Operationsh cycles (OW OFF) a a Fixed mounting Ww 36 a Veight T a a Total opening delay on non-delayed short-circuit release (up to the cycle act of the c	up to 690 V 50/60 Hz	I _{cs}	kA	42
Total opening delay via shunt release ms 30 Total opening delay via undervoltage release ms 50 Total opening delay on non-delayed short-circuit release (up to complete or quenching) ms 27 Lifespan, mechanical Svitching cycles (OW OFF) ms 25000000000000000000000000000000000000	Operating times			
Total opening delay via undervoltage release Image: Solution of the solution of	Closing delay via spring release		ms	30
Total opening delay on non-delayed short-circuit release (up to complete are quenching) ms 27 Lifespan, mechanical Switching cycles (0N) or cycles (0N)	Total opening delay via shunt release		ms	30
quenching) I Lifespan S Lifespan, mechanical Svitching cycles (ON OFF) I2500- Lifespan, mechanical with maintenance Svitching cycles (ON OFF) 25000. Lifespan, electrical Svitching cycles (ON OFF) 10000 Lifespan, electrical with maintenance Svitching cycles (ON OFF) 10000. Maximum operating frequency Operationsh 60 Heat dissipation at rated current In W 36 Fixed mounting Maximum operating frequency Maximum operating frequency Jopela W 36 Veight Terminal capacities Svitching cycles (ON OFF) Japola Maximum operating frequency Maximum operating frequency Jopela Weight Source (Stitching cycles (St	Total opening delay via undervoltage release		ms	50
quenching) S Lifespan, mechanical Svitching cycles (DN) OFF 12500- Lifespan, mechanical with maintenance Svitching cycles (DN) OFF 25000. Lifespan, electrical Svitching cycles (DN) OFF 10000 Lifespan, electrical Svitching cycles (DN) OFF 10000. Lifespan, electrical with maintenance Svitching cycles (DN) OFF 10000. Maximum operating frequency Operationsh 60 Heat dissipation at rated current In W 36 Fixed mounting Maximum operating frequency W Japole W 36 Terminal Capacities Maximum operating frequency W Spole Maximum operating frequency Maximum operating frequency Japole W 36 Terminal Capacities Maximum operating frequency Maximum operating frequency Japole Maximum operating frequency Maximum operating frequency Maximum operating frequency Spole Terminal Capacities Maximum operating frequency Maximum operating frequency Japole State operating frequency State operating frequency Maximum operating frequency <td></td> <td></td> <td></td> <td></td>				
Lifespan, mechanical Switching cycles (01/ Cycles (01/ Cycles (01/ Lifespan, electrical Switching cycles (01/ Cycles (01/ Cyc			ms	27
If espan, mechanical with maintenance Switching cycles (ON/OFF) S000. Lifespan, electrical Switching cycles (ON/OFF) 10000 Lifespan, electrical with maintenance Switching cycles (ON/OFF) 0000. Lifespan, electrical with maintenance Switching cycles (ON/OFF) 0000. Maximum operating frequency Operations/n 0000. Heat dissipation at rated current In W 36 Fixed mounting W 36 Veright Image: State S	Lifespan		S	
if is pan, electrical cycles (0N/ cycles (0N/ OFF) 0000 Lifespan, electrical with maintenance Switching cycles (0N/ OFF) 20000. Maximum operating frequency Operations/h (Perations/h) 60 Heat dissipation at rated current In W 36 Fixed mounting W 36 Weight	Lifespan, mechanical	cycles (ON/		12500
cycles (0N/ OFF) cycles (0N/ OFF) 20000. Maximum operating frequency Operations/h (0FF) 60 Heat dissipation at rated current In 60 Fixed mounting W 36 Weight Fixed mounting Image: Construct of the second	Lifespan, mechanical with maintenance	cycles (ON/		25000.
cycles (0V/ OFF) G Maximum operating frequency Operations/h 60 Heat dissipation at rated current In W 36 Fixed mounting W 36 Weight Terminal capacities Copper bar Fixed mounting Maximum operating frequency Black Mmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmmm	Lifespan, electrical	cycles (ON/		10000
Heat dissipation at rated current In Image: Constraint of the constraint o	Lifespan, electrical with maintenance	cycles (ON/		20000.
Fixed mounting W 36 Veight Fixed mounting Image: Section 2000 (Section 2000) (Section 2000	Maximum operating frequency	Operations/h		60
Weight Fixed mounting Image: Stand	Heat dissipation at rated current In			
Weight Fixed mounting Image: Stand	Fixed mounting		W	36
Fixed mounting Image: Comparison of the second of the	-			
Terminal capacities Copper bar Image: Copper bar result in the specific switchgear can provide Fixed mounting Image: Copper bar result in the specific switchgear can provide Black Image: Copper bar result in the specific switchgear can provide	_			
Copper bar Fixed mounting Fixed mounting mm 2 x 5 x 50 Black These are values used in separate switchgear. The actual values will depend on the temperature around the circuit-breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross-sectional area. Temperature rise tests in the specific switchgear can provide	3-pole		kg	19
Fixed mounting mm 2 x 5 x 50 Black These are values used in separate switchgear. The actual values will depend on the temperature around the circuit-breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross-sectional area. Temperature rise tests in the specific switchgear can provide	-			
Black mm 2 x 5 x 50 These are values used in separate switchgear. The actual values will depend on the temperature around the circuit-breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross-sectional area. Temperature rise tests in the specific switchgear can provide	Copper bar			
These are values used in separate switchgear. The actual values will depend on the temperature around the circuit-breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross- sectional area. Temperature rise tests in the specific switchgear can provide	Fixed mounting			
the temperature around the circuit-breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross- sectional area. Temperature rise tests in the specific switchgear can provide	Black		mm	2 x 5 x 50
specific and detailed information.				the temperature around the circuit-breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross-

Permissible continuous current for circuit-breakers operating in switchboards at various internal ambient temperatures. The switchboard's internal ambient temperature should be estimated using the calculation methods of IEC regulation.

Design verification as per IEC/EN 61439

chnical data for design verification			
Rated operational current for specified heat dissipation	I _n	А	630
Equipment heat dissipation, current-dependent	P _{vid}	W	36
Operating ambient temperature min.		°C	-20
Operating ambient temperature max.		°C	70
C/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

Rated permanent current lu	А	630
Rated voltage	V	690 - 690
Rated short-circuit breaking capacity Icu at 400 V, 50 Hz	kA	65
Overload release current setting	А	315 - 630
Adjustment range short-term delayed short-circuit release	А	1260 - 6300
Adjustment range undelayed short-circuit release	А	1260 - 7560
Integrated earth fault protection		No
Type of electrical connection of main circuit		Rail connection
Device construction		Built-in device fixed built-in technique
Suitable for DIN rail (top hat rail) mounting		No
DIN rail (top hat rail) mounting optional		No
Number of auxiliary contacts as normally closed contact		0
Number of auxiliary contacts as normally open contact		0
Number of auxiliary contacts as change-over contact		2

With switched-off indicator	Yes
With under voltage release	No
Number of poles	3
Position of connection for main current circuit	Back side
Type of control element	Push button
Complete device with protection unit	Yes
Motor drive integrated	No
Motor drive optional	Yes
Degree of protection (IP)	IP31

Dimensions

