


Relay module for NZM2/3, configurable, 2NO, 24DC, 24-230AC, PI

Part no. **NZM2/3-X2A**  
 Catalog No. **189722**

Similar to illustration

**Delivery program**

Product range		Accessories
Accessories		Relay module I
Accessories		Relay module
Standard/Approval		UL/CSA, IEC
Construction size		NZM2/3
Description		For signaling commands or different states of the circuit-breaker. Two relays per unit. The activation criteria can be configured in the trip unit. Configuration via communication or circuit breaker display or front USB port and Eaton Power Xpert Protection Manager. Only for use in combination with circuit-breakers with electronic trips. Relay components cannot be installed simultaneously with make-before-break auxiliary breaker NZM...-XHIV, the under-voltage trip NZM...-XU.... or the shunt trip NZM...-XA.... Relay contacts for control wiring. Relays can be used for controlling remote operator with $U_s=208-204$ V AC. Control wiring on push-in clamps. Cannot be used with the PXR10 NZM-AX electronic trip.
Connection type		with push in terminal
For use with		PXR20(25) NZM2(-4)-.X... PXR20(25) NZM3(-4)-.X...
Number of relays		2
Contact sequence		

**Technical data**

**Relay contacts**

Rated control voltage	$U_s$	V	
AC	$U_s$	V AC	24 - 240
DC	$U_s$	V DC	24 - 24
Contacts			
Rated impulse withstand voltage	$U_{imp}$	V AC	4000
Rated insulation voltage	$U_i$	V	250
Overtoltage category/pollution degree			II/2
Switching capacity		$kA_{rms}$	
Rated operational current			
AC-1			
24 V	$I_e$	A	1
110 V	$I_e$	A	1
230 V	$I_e$	A	1
DC-1			
24 V	$I_e$	A	1
Min. switching capacity (reference value)			0.1 mA / 0.1 VDC

Connection		
Stripping length	mm	8
<b>Terminal capacity</b>		
Solid	mm <sup>2</sup>	1 x (0.2 – 1.5)
Stranded	mm <sup>2</sup>	1 x (0.25 – 1.5)
	AWG	1 x (24 - 16)
with insulated end sleeve in accordance with DIN46224 / 4	mm <sup>2</sup>	1 x (0,25 - 1,5)
with uninsulated end sleeve in accordance with DIN46228 / 1	mm <sup>2</sup>	1 x (0,25 - 0,75)

## Design verification as per IEC/EN 61439

IEC/EN 61439 design verification		
10.2 Strength of materials and parts		
10.2.2 Corrosion resistance		Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures		Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat		Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects		Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation		Meets the product standard's requirements.
10.2.5 Lifting		Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact		Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions		Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES		Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances		Meets the product standard's requirements.
10.5 Protection against electric shock		Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components		Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections		Is the panel builder's responsibility.
10.8 Connections for external conductors		Is the panel builder's responsibility.
10.9 Insulation properties		
10.9.2 Power-frequency electric strength		Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage		Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material		Is the panel builder's responsibility.
10.10 Temperature rise		The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function		The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Accessories for low-voltage switch technology (EC002498)		
Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Component for low-voltage switch technology (accessories) (ecl@ss10.0.1-27-37-13-92 [AKN570013])		
Type of accessory		Other

## Approvals

Product Standards		UL489; CSA-C22.2 No. 5-09; IEC60947, CE marking
UL File No.		E140305
UL Category Control No.		DIHS
CSA File No.		022086
CSA Class No.		1437-01
North America Certification		UL listed, CSA certified

## Additional product information (links)

<b>IL012141ZU shunt trip, under-voltage trip, leading auxiliary contact</b>
---

