## **DATASHEET - NZMS3-4-VX400**



## NZM3 PXR20 circuit breaker, 400A, 4p, screw terminal

Powering Business Worldwide™

NZMS3-4-VX400 Part no. Catalog No. 191521

Similar to illustration

Delivery program			
Product range			Circuit-breaker
Protective function			Systems, cable, selectivity and generator protection
Standard/Approval			IEC
Installation type			Fixed
Release system			Electronic release
Construction size			NZM3
Description			LSI overload protection and delayed and non-delayed short-circuit protective device R.m.s. value measurement and "thermal memory" USB interface for configuration and test function with Power Xpert Protection Manager software Optionally communication-capable with interface module and internal Modbus RTU module or CAM
Number of poles			4 pole
Standard equipment			Screw connection
Switching capacity			
400/415 V 50 Hz	I <sub>cu</sub>	kA	70
Rated current = rated uninterrupted current			
Rated current = rated uninterrupted current	$I_n = I_u$	Α	400
Neutral conductor	% of phase conductor	%	100
Setting range			
Overload trip			
中	I <sub>r</sub>	Α	160 - 400
Short-circuit releases			
Non-delayed	$I_i = I_n x \dots$		2 – 12
Delayed	$I_{sd} = I_r x \dots$		2 – 10

## **Technical data**

#### General

delleral		
Standards		IEC/EN 60947
Protection against direct contact		Finger and back of hand proof to VDE 0106 Part 100
Climatic proofing		Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ambient temperature		
Ambient temperature, storage	°C	- 40 - + 70
Operation	°C	-25 - +70
Mechanical shock resistance (10 ms half-sinusoidal shock) according to IEC 60068-2-27	g	20 (half-sinusoidal shock 20 ms)
Safe isolation to EN 61140		

Between auxiliary contacts and main contacts		V AC	500	
between the auxiliary contacts		V AC	300	
Mounting position			Vertical and 90° in all directions	With XFI earth-fault release: - NZM1, N1, NZM2, N2: vertical and 90° in all directions with plug-in unit - NZM1, N1, NZM2, N2: vertical, 90° right/left with withdrawable unit: - NZM3, N3: vertical, 90° right/left - NZM4, N4: vertical with remote operator: - NZM2, N(S)2, NZM3, N(S)3, NZM4, N(S)4: vertical and 90° in all directions
Direction of incoming supply			as required	
Degree of protection				
Device			In the operating controls area: IP2	0 (basic degree of protection)
Enclosures			With insulating surround: IP40 With door coupling rotary handle:	IP66
Terminations			Tunnel terminal: IP10 Phase isolator and strip terminal: I	P00
Other technical data (sheet catalogue)			Temperature dependency, Deratin	g
Circuit-breakers				
Rated current = rated uninterrupted current	$I_n = I_u$	Α	400	
Rated surge voltage invariability	U <sub>imp</sub>			
Main contacts		V	8000	
Auxiliary contacts		V	6000	
Rated operational voltage	U <sub>e</sub>	V AC	690	
Overvoltage category/pollution degree			III/3	
Rated insulation voltage	Ui	V	690	
Jse in unearthed supply systems		V	≦ 690	
Switching capacity				
Rated short-circuit making capacity	I <sub>cm</sub>			
240 V	I <sub>cm</sub>	kA	220	
400/415 V	I <sub>cm</sub>	kA	154	
440 V 50/60 Hz	I <sub>cm</sub>	kA	143	
525 V 50/60 Hz	I <sub>cm</sub>	kA	80	
690 V 50/60 H	Ic	kA	50	
Rated short-circuit breaking capacity I <sub>cn</sub>	I <sub>cn</sub>			
Icu to IEC/EN 60947 test cycle 0-t-C0	Icu	kA		
240 V 50/60 Hz	I <sub>cu</sub>	kA	100	
400/415 V 50/60 Hz	I <sub>cu</sub>	kA	70	
440 V 50/60 Hz	I <sub>cu</sub>	kA	65	
525 V 50/60 Hz	I <sub>cu</sub>	kA	36	
690 V 50/60 Hz	I <sub>cu</sub>	kA	25	
Ics to IEC/EN 60947 test cycle 0-t-C0-t-C0	Ics	kA		
240 V 50/60 Hz	I <sub>cs</sub>	kA	100	
400/415 V 50/60 Hz	I <sub>cs</sub>	kA	70	
440 V 50/60 Hz	I <sub>cs</sub>	kA	65	
525 V 50/60 Hz	I <sub>cs</sub>	kA	18	
690 V 50/60 Hz	I <sub>cs</sub>	kA	6	
				ected short-circuit currents at the installation acity of the circuit-breaker.
Rated short-time withstand current				
t = 0.3 s	I <sub>cw</sub>	kA	3.3	
t=1s	I <sub>cw</sub>	kA	3.3	
Jtilization category to IEC/EN 60947-2			A	

Lifespan, electrical			
AC-1			
400 V 50/60 Hz	Operations		5000
415 V 50/60 Hz	Operations		5000
690 V 50/60 Hz	Operations		3000
Max. operating frequency		Ops/h	60
Total break time at short-circuit		ms	<10
Terminal capacity			
Standard equipment			Screw connection
Optional accessories			Box terminal Tunnel terminal connection on rear
Round copper conductor			
Box terminal			
Solid		mm <sup>2</sup>	2 x 16
Stranded		mm <sup>2</sup>	1 x (35 - 240) 2 x (25-120)
Tunnel terminal			
Solid		mm <sup>2</sup>	1 x 16
Stranded			
1-hole		mm <sup>2</sup>	1 x (16 - 185)
Bolt terminal and rear-side connection			
Direct on the switch			
Solid		mm <sup>2</sup>	1 x 16 2 x 16
Stranded		$mm^2$	1 x (25 - 240) 2 x (25 - 240)
Connection width extension		mm <sup>2</sup>	
Connection width extension		mm <sup>2</sup>	2 x 300
Al circular conductor			
Tunnel terminal			
Solid		mm <sup>2</sup>	1 x 16
Stranded		111111	
Stranded		mm <sup>2</sup>	1 x (25 - 185) <sup>2)</sup>
Double hole		mm <sup>2</sup>	1 x (50 - 240) 2 x (50 - 240)
			$^{2)}$ Up to 240 $\mathrm{mm^2}$ can be connected depending on the cable manufacturer.
Cu strip (number of segments x width x segment thickness)			
Box terminal			
	min.	mm	6 x 16 x 0.8
	max.	mm	10 x 24 x 1.0 + 5 x 24 x 1.0
			(2 x) 8 x 24 x 1.0
Bolt terminal and rear-side connection			
Flat copper strip, with holes	min.	mm	6 x 16 x 0.8
Flat copper strip, with holes	max.	mm	10 x 32 x 1.0 + 5 x 32 x 1.0
Connection width extension		mm	(2 x) 10 x 50 x 1.0
Copper busbar (width x thickness)	mm		
Bolt terminal and rear-side connection			Min
Screw connection			M10
Direct on the switch	min	mm	20 v 5
	min.	mm	20 x 5 30 x 10
	max.	mm	30 x 10 + 30 x 5
Connection width extension		mm	
Connection width extension	max.	mm	2 x (10 x 50)
Control cables			
		$\mathrm{mm}^2$	1 x (0.75 - 2.5)

## Design verification as per IEC/EN 61439

provide heat dissipation data for the devices.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	besign vermoution as per 120/214 01-105			
Equipment heat dissipation, current-dependent  Operating ambient temperature min.  Operating ambient temperature max.  10.2 Foreign ambient temperature max.  10.2 Strength of materials and parts  10.2 Strength of materials and parts  10.2.2 Corrosion resistance  10.2.3.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  10.2 Incorpions  10.3 Degree of protection of ASSEMBLIES  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.8 Connections for external conductors  10.9 Insulation properties  10.10 Temperature rise  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction observed.  10.13 Mechanical function	Technical data for design verification			
Operating ambient temperature min. Operating ambient temperature max.  10.2 Strength of materials and parts 10.2 Strength of materials and parts 10.2.3 Verification of thermal stability of enclosures 10.2.3.1 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to abnormal heat 10.2.3.2 Verification of resistance of insulating materials to abnormal heat 10.2.3.2 Verification of resistance of insulating materials to abnormal heat 10.2.3.2 Verification of resistance of insulating materials to abnormal heat 10.2.3 Verification of resistance of insulating materials to abnormal heat 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Resistance of insulations for the switchgear must observed. 10.15 The device meets the requirements, provided the information in the instruction 10.15 The device meets the requirements, provided the information in the instruction 10.15 The device meets the requirements, provided the information in the instruction 10.15 The device meets the requirements, provided the information in the instruction	Rated operational current for specified heat dissipation	In	Α	400
Operating ambient temperature max.  10.2 Strength of materials and parts  10.2.2 Corrosion resistance  10.2.3 I Verification of thermal stability of enclosures  10.2.3 Verification of thermal stability of enclosures  10.2.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Mechanical impact  10.2.5 Mechanical impact  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3 Degree of protection of ASSEMBLIES  10.4 Gearances and creepage distances  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electric al circuit sand connections  10.8 Connections for external conductors  10.9 Insulation properties  10.9 Insulation properties  10.9 Insulation properties  10.9 Insulation properties  10.10 Temperature rise  10.10 Temperature rise  10.11 Short-circuit rating  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction of basic constraints in the instruction of the switchgear must observed.  10.10 Temperature rise  10.11 Short-circuit rating  10.11 Short-circuit rating  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction of the constraints in the instruction of the switchgear must observed.	Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	48
IEC/EN 81439 design verification   10.2 Strength of materials and parts   10.2.2 Corrosion resistance   Meets the product standard's requirements.   10.2.3.1 Verification of thermal stability of enclosures   Meets the product standard's requirements.   10.2.3.2 Verification of resistance of insulating materials to normal heat   Meets the product standard's requirements.   10.2.3.2 Verification of resistance of insulating materials to abnormal heat   Meets the product standard's requirements.   10.2.3 Verification of resistance of insulating materials to abnormal heat   Meets the product standard's requirements.   10.2.4 Resistance to ultra-violet (UV) radiation   Meets the product standard's requirements.   10.2.5 Lifting   Does not apply, since the entire swritchgear needs to be evaluated.   10.2.5 Mechanical impact   Does not apply, since the entire swritchgear needs to be evaluated.   10.3.1 Degree of protection of ASSEMBLIES   Does not apply, since the entire swritchgear needs to be evaluated.   10.4 Clearances and creepage distances   Meets the product standard's requirements.   10.5 Protection against electric shock   Does not apply, since the entire swritchgear needs to be evaluated.   10.5 Incorporation of swritching devices and components   Does not apply, since the entire swritchgear needs to be evaluated.   10.5 Incorporation of swritching devices and components   Does not apply, since the entire swritchgear needs to be evaluated.   10.5 Incorporation of swritching devices and components   Does not apply, since the entire swritchgear needs to be evaluated.   10.5 Incorporation of swritching devices and components   Is the panel builder's responsibility.   10.5 Incorporation of swritching devices and components   Is the panel builder's responsibility.   10.5 Incorporation	Operating ambient temperature min.		°C	-25
10.2 Strength of materials and parts 10.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to abnormal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3.0 Pagree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.3 Impulse withstand voltage 10.9.4 Stating of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.14 Clearances and composibility 10.15 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Incorporation of switching devices and components 10.9 Insulation propreties 10.9.1 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.1 Feeting of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Meets the product standard's requirements. 10.15 Meets the product standard's requirements. 10.16 Meets the product standard's requirements. 10.17 Meets the product standard's requirements. 10.18 Meets the product standard's requirements. 10.19 Meets the product standard's requirements. 10.19 Meets the product standard's requirements. 10.10 Temperature rise exponsibili	Operating ambient temperature max.		°C	70
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions  10.3 Degree of protection of ASSEMBLIES 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electric criteriats and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.10 Temperature rise 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements. 10.17 Meets the product standard's requirements. 10.18 Meets the product standard's requirements. 10.19 Meets the product standard's requirements. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechani	IEC/EN 61439 design verification			
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.3 Degree of protection of ASSEMBLIES 10.3 Degree of protection of switching devices and components 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9 Power-frequency electric strength 10.9.1 Responsibility. 10.9 Temperature rise 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function  Meets the product standard's requirements.  Meets the product standard's requirements.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.  Is the panel builder's responsibility. The specifications for the switchgear mus observed.  Is the panel builder's responsibility. The specifications for the switchgear mus observed.  Is the panel builder's responsibility. The specifications for the switchgear mus observed.	10.2 Strength of materials and parts			
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.  Is the panel builder's responsibility.  It has pacifications for the switchgear must observed.  In the device meets the equirements, provided the informatio	10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10.2.6 Mechanical impact  10.2.6 Mechanical impact  10.2.7 Inscriptions  10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9 Power-frequency electric strength  10.9 Power-frequency electric istrength  10.9.1 Resting of enclosures made of insulating material  10.10 Temperature rise  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Meets the product standard's requirements.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.  Is the panel builder's responsibility.  Is the panel builder's responsibility.  10.10 Temperature rise  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.12 Electromagnetic compatibility  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  Does not apply, since the entire switchgear needs to be evaluated.  10.2.6 Mechanical impact  Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of ASSEMBLIES  Does not apply, since the entire switchgear needs to be evaluated.  10.4 Clearances and creepage distances  Meets the product standard's requirements.  10.5 Protection against electric shock  Does not apply, since the entire switchgear needs to be evaluated.  10.6 Incorporation of switching devices and components  Does not apply, since the entire switchgear needs to be evaluated.  10.7 Internal electrical circuits and connections  Is the panel builder's responsibility.  10.8 Connections for external conductors  Is the panel builder's responsibility.  10.9 Insulation properties  10.9.2 Power-frequency electric strength  Is the panel builder's responsibility.  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  The panel builder's responsibility.  10.11 Short-circuit rating  Lis the panel builder's responsibility.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Clevice meets the requirements, provided the information in the instruction 10.15 Product standard's requirements. 10.16 Power standard's requirements. 10.17 Internal electrical circuits and connections 10.18 Connections for external conductors 10.19 Insulation properties 10.19 The panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Clearances and crepage distances 10.15 Protection against electric stands to be evaluated. 10.16 Incorporation of ASSEMBLIES 10.17 Internal electric standard's requirements. 10.18 Clearances and creepage distances 10.19 Insulation properties 10.19 Insulat				Meets the product standard's requirements.
Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 Inscriptions  Meets the product standard's requirements.  10.3 Degree of protection of ASSEMBLIES  Does not apply, since the entire switchgear needs to be evaluated.  10.4 Clearances and creepage distances  Meets the product standard's requirements.  10.5 Protection against electric shock  Does not apply, since the entire switchgear needs to be evaluated.  10.6 Incorporation of switching devices and components  Does not apply, since the entire switchgear needs to be evaluated.  10.7 Internal electrical circuits and connections  Is the panel builder's responsibility.  10.8 Connections for external conductors  Is the panel builder's responsibility.  10.9.1 Insulation properties  10.9.2 Power-frequency electric strength  Is the panel builder's responsibility.  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  The panel builder is responsibility.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
Meets the product standard's requirements.  10.3 Degree of protection of ASSEMBLIES  Does not apply, since the entire switchgear needs to be evaluated.  10.4 Clearances and creepage distances  Meets the product standard's requirements.  10.5 Protection against electric shock  Does not apply, since the entire switchgear needs to be evaluated.  10.6 Incorporation of switching devices and components  Does not apply, since the entire switchgear needs to be evaluated.  10.7 Internal electrical circuits and connections  Is the panel builder's responsibility.  10.9 Rounections for external conductors  Is the panel builder's responsibility.  10.9.1 Insulation properties  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  Is the panel builder's responsibility.  10.10 Temperature rise  The panel builder's responsibility.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.12 Electromagnetic compatibility  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of ASSEMBLIES  10.4 Clearances and creepage distances  Meets the product standard's requirements.  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9 Insulation properties  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.  In provide heat dissipation data for the devices.  Is the panel builder's responsibility.  Is the panel builder's responsibility.  Is the panel builder's responsibility.  The specifications for the switchgear must observed.  Is the panel builder's responsibility. The specifications for the switchgear must observed.	10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances  10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9 Insulation properties  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  10 sthe panel builder's responsibility.  Is the panel builder is responsibility.  Is the panel builder is responsibility.  Is the panel builder is responsibility.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  Is the panel builder's responsibility. The specifications for the switchgear must observed.	10.2.7 Inscriptions			Meets the product standard's requirements.
10.5 Protection against electric shock  10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9 Insulation properties  10.9.2 Power-frequency electric strength  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.  Is the panel builder's responsibility.  The panel builder's responsibility.  Is the panel builder is responsibility.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components  10.7 Internal electrical circuits and connections  10.8 Connections for external conductors  10.9 Insulation properties  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.  Is the panel builder's responsibility.  Is the panel builder's responsibility.  The panel builder is responsibility.  Is the panel builder is responsibility.  Is the panel builder's responsibility.  The specifications for the switchgear must observed.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  The device meets the requirements, provided the information in the instruction.	10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.7 Internal electrical circuits and connections  1s the panel builder's responsibility.  10.8 Connections for external conductors  1s the panel builder's responsibility.  10.9 Insulation properties  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  1s the panel builder's responsibility.  10.9.4 Testing of enclosures made of insulating material  1s the panel builder's responsibility.  10.10 Temperature rise  The panel builder is responsibility for the temperature rise calculation. Eaton with provide heat dissipation data for the devices.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors  10.9 Insulation properties  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Is the panel builder's responsibility.  Is the panel builder's responsibility.  Is the panel builder is responsibility.  Is the panel builder is responsibility.  Is the panel builder's responsibility.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  In the panel builder's responsibility. The specifications for the switchgear must observed.  The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.9 Insulation properties  10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Is the panel builder's responsibility.  Is the panel builder's responsibility.  The panel builder is responsible for the temperature rise calculation. Eaton we provide heat dissipation data for the devices.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength  10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Is the panel builder's responsibility.  Is the panel builder's responsibility.  The panel builder is responsible for the temperature rise calculation. Eaton with provide heat dissipation data for the devices.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage  10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  10.11 Short-circuit rating  10.12 Electromagnetic compatibility  10.13 Mechanical function  Is the panel builder's responsibility.  The panel builder is responsible for the temperature rise calculation. Eaton we provide heat dissipation data for the devices.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  Is the panel builder's responsibility. The specifications for the switchgear must observed.  The device meets the requirements, provided the information in the instruction	10.9 Insulation properties			
10.9.4 Testing of enclosures made of insulating material  10.10 Temperature rise  The panel builder is responsible for the temperature rise calculation. Eaton with provide heat dissipation data for the devices.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.10 Temperature rise  The panel builder is responsible for the temperature rise calculation. Eaton we provide heat dissipation data for the devices.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
provide heat dissipation data for the devices.  10.11 Short-circuit rating  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
observed.  10.12 Electromagnetic compatibility  Is the panel builder's responsibility. The specifications for the switchgear must observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
observed.  10.13 Mechanical function  The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
	10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
lealiet (IL) is observed.	10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

#### **Technical data ETIM 7.0**


Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

,	А	400
\	V	690 - 690
ŀ	kA	70
,	A	160 - 400
,	A	2 - 10
1	A	2 - 12
		No
		Screw connection
		Built-in device fixed built-in technique
		No
		No
		0
		0
		0
		No
		No
		A V kA A A


Number of poles	4
Position of connection for main current circuit	Front side
Type of control element	Rocker lever
Complete device with protection unit	Yes
Motor drive integrated	No
Motor drive optional	Yes
Degree of protection (IP)	IP20


## **Characteristics**





# **Dimensions**





#### Additional product information (links)

Additional product information (links)				
IL012100ZU NZM3-PXR circuit-breaker, basic device , NZM3-PXR Circuit-Breaker, basic unit				
IL012100ZU NZM3-PXR circuit-breaker, basic device , NZM3-PXR Circuit-Breaker, basic unit	https://es-assets.eaton.com/DOCUMENTATION/AWA_INSTRUCTIONS/IL012100ZU2020_10.pdf			
Temperature dependency, Derating	http://ecat.moeller.net/flip-cat/?edition=HPLEN&startpage=17.172			
additional technical information for NZM power switch	https://es-assets.eaton.com/DOCUMENTATION/PDF/nzm_technic_de_en.pdf			