DATASHEET - NZM1-XU208-240AC



Undervoltage release, 208-240VAC

NZM1-XU208-240AC 259442

0004358718

EL-Nummer

Part no.

Catalog No.

(Norway)



Delivery program

Product range			Accessories
Accessories			Undervoltage release
Accessories			Undervoltage releases
Standard/Approval			UL/CSA, IEC
Construction size			NZM1
Description			Non-delayed disconnection of NZM circuit-breaker or N switch-disconnector when the control voltage sinks below 35 – 70% U _S . For use with emergency-stop devices in connection with an emergency-stop button. When the under-voltage trip is switched off, accidental contact with the circuit breaker's primary contacts is prevented when switched on. Undervoltage releases cannot be installed simultaneously with NZMXHIV early-make auxiliary contact or NZMXA shunt release.
Connection type			with terminal block on the left-hand switch side
Auxiliary contacts			without auxiliary contact
Rated control voltage	Us	V	208 - 240 V 50/60 Hz
For use with			NZM1(-4), N(S)1(-4)

Technical data

Undervoltage release			
Rated control voltage	Us	V	
AC	Us	V AC	208 - 240
Rated control voltage	Us	V	208 - 240 V 50/60 Hz
Operating range			
Drop-out voltage		x U _s	0.35 - 0.7
Pick-up voltage	x Uc		0.85 - 1.1
Power consumption			
AC			
Pick-up AC		VA	1.5
Sealing AC		VA	1.5
DC		x U _s	
Pick-up DC		W	0.8
Sealing DC		W	0.8
Maximum opening delay (response time until opening of the main contacts)		ms	19
Minimum command time		ms	10 - 15
Terminal capacities			
Solid or flexible conductor, with ferrule		mm ²	1 x (0,75 - 2,5) 2 x (0,75 - 2,5)
		AWG	1 x (18 14) 2 x (18 14)

Design verification as per IEC/EN 61439

IEC/EN 61439 design verification
Image: Constant of materials and parts
Image: Constant of materials and parts

10.2 Strength of materials and parts
Image: Constant of materials and parts
Image: Constant of materials and parts

10.2.2 Corrosion resistance
Image: Constant of thermal stability of enclosures
Image: Constant of thermal stability of enclosures

10.2.3.1 Verification of thermal stability of enclosures
Image: Constant of thermal stability of enclosures
Image: Constant of thermal stability of enclosures

10.2.3.2 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects
Image: Constant of thermal stability of enclosures
Image: Constant of the product standard's requirements.

10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects
Image: Constant of the product standard's requirements.

10.2.4 Resistance to ultra-violet (UV) radiation
Image: Constant of the product standard's requirements.

10.2.4 Resistance to ultra-violet (UV) radiation
Image: Constant of the product standard's requirements.

10.2.4 Resistance to ultra-violet (UV) radiation
Image: Constant of the product standard's requirements.

Image: Constant of the product standard's requirements.
Image: Constant of the product standard's requirements.

Image: Constant of the product standard's requirements.
Image: Constant of the product standar

10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0


Low-voltage industrial components ((EG000017) / Under voltage coil (EC001022)
-------------------------------------	--

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Undervoltage trip (ecl@ss10.0.1-27-37-04-17 [AKF015013])		
Rated control supply voltage Us at AC 50HZ	V	208 - 240
Rated control supply voltage Us at AC 60HZ	V	208 - 240
Rated control supply voltage Us at DC	V	0 - 0
Voltage type for actuating		AC
Type of electric connection		Screw connection
Number of contacts as normally open contact		0
Number of contacts as normally closed contact		0
Number of contacts as change-over contact		0
Delayed		No
Suitable for power circuit breaker		Yes
Suitable for off-load switch		Yes
Suitable for motor safety switch		No
Suitable for overload relay		No

Approvals

Product Standards	UL489; CSA-C22.2 No. 5-09; IEC60947, CE marking
UL File No.	E140305
UL Category Control No.	DIHS
CSA File No.	022086
CSA Class No.	1437-01
North America Certification	UL listed, CSA certified

Dimensions



2 NZM1-XA(HIV)(L) NZM1-XU(V)(HIV)(L)(20) NZM1-XHIV(L) ③ NZM1-XHIVR

Additional product information (links)

IL01203002Z (AWA1230-1914) Shunt release, Undervoltage release, Early-make auxiliary contact

IL01203002Z (AWA1230-1914) Shunt release, Undervoltage release, Early-make auxiliary contact

https://es-assets.eaton.com/DOCUMENTATION/AWA_INSTRUCTIONS/IL01203002Z2010_11.pdf